Airport **Division:** Member: Alex Erskine

954-828-4966

Project Roy Magac Case #: 64 R 03

Name:

July 8, 2003 Date:

Comments:

1. No Comments.

Division: Engineering **Member:** Tim Welch

Engineering Design Mgr.
Office Ph. 954-828-5123
Office Fax: 954-828-5275
Email: timw@cityfort.com

Project Roy Magac Case #: 64 R 03

Name:

Date: July 8, 2003

Comments:

1. Comments will be available at the meeting.

Division: Fire **Member:** Albert Weber

954-828-5875

Project Roy Magac Case #: 64 R 03

Name:

Date: July 8, 2003

Comments:

1. Fire sprinkler systems required at permit.

2. Show all fire mains and sprinkler mains on civil plans.

3. Show hydrants.

DRC <u>SITE PLAN REVIEW AND COMMENT</u> <u>REPORT</u>

Division: Info. Systems **Member:** Mark Pallans

(GRG)

954-828-5790

Project Roy Magac Case #: 64 R 03

Name:

Date: July 8, 2003

Comments:

1. No apparent interference will result from this plan at this time.

Division: Landscape Member: Dave Gennaro

954-828-5200

Project Roy Magac Case #: 64 R 03

Name:

Date: July 8, 2003

Comments:

1. All Tree Preservation Ordinance requirements apply. Equivalent replacement for trees removed to above min.site Code requirements.

2. Add rain sensor requirement to irrigation note.

Division: Planning **Member:** Lois Udvardy

954-828-5862

loisu@cityfort.com

Project Roy Magac Case #: 64 R 03

Name:

Date: July 8, 2003

Site plan approval/Five (5) townhomes/RC-15 1734 N.E. 7 St.

Comments:

1. Provide one (1) updated survey of entire parcel.

- 2. Provide a table indicating the required and proposed setbacks for the project. This table is to be indicated on the site plan as part of the site plan data information.
- 3. Provide a point-by-point narrative outlining compliance with Sec. 47-18.33, Townhouse and compliance.
- 4. Provide a point-by-point narrative indicating how this project meets Sec. 47-25.2, Adequacy Requirements.
- 5. Per Sec. 47-18.33.6. Entrance requirements, within RC-15 district, any principle structure's façade facing a public right-of-way shall be considered the front façade for those units. Each unit must have, on a front façade, it own principal entrance. The entrance shall be a roofed concrete landing a minimum of three (3) feet by five (5) feet and shall be of architectural design and material similar to and integral with the principal structure.
- 6. Sec. 47-18.33.B.3. requires a minimum of twenty-five percent (25%) of the townhouse groups front façade be setback an additional five (5) feet from the rest of the front façade. This requirement has not been met.
- 7. Pools and decks cannot be located in easement.
- 8. Pursuant to Sec. 47-19.2.B, Accessory uses which encroach into any yard area cannot have a total combined linear façade length greater than 20% of the total linear length of the façade to which they are attached. Provide percentages for balconies.

DRC <u>SITE PLAN REVIEW AND COMMENT</u> <u>REPORT</u>

- 9. Indicate outline of adjacent buildings on site plan and elevations.
- 10. Show relationship to streets on elevations.
- 11. Indicate location of mechanical equipment on site plan.
- 12. Provide elevation at grade.
- 13. Discuss setbacks with Zoning.
- 14. Provide additional architectural detailing on east and west elevations.
- 15. Discuss providing a different type of street trees (shade instead of palm) with Landscape representative.
- 16. It is strongly suggested that this plan be presented to Victoria Park Civic Assn.
- 17. Provide a response to all DRC comments within 90 days or additional DRC review may be required.
- 18. Additional comments may be forthcoming at DRC meeting.

DRC <u>SITE PLAN REVIEW AND COMMENT</u> <u>REPORT</u>

Division: Police Member: Detective Nate Jackson

Office-954-828-6422 Pager-954-877-7875 Fax -954-828-6423

Project Roy Magac Case #: 64 R 03

Name:

Date: July 8, 2003

Comments:

1. Recommend that garage door controls are equipped with a panic alarm system.

- 2. All glass doors/windows are to adhere to S.F.B.C.
- 3. Recommend intrusion/fire alarm system
- 4. Recommend addition lighting at the garage entry.

Division: Zoning Member: Terry Burgess

954-828-5913

Project Roy Magac Case #: 64 R 03

Name:

Date: July 8, 2003

Comments:

1. A narrative outlining how the proposed townhouse project complies with section 47-18.33 section by section.

- 2. Provide a data table indicating the required and provided setbacks pursuant to section 47-18.33.
- 3. Within the RC-15 districts only, any principal structure's façade facing a public right-of-way shall be considered the front façade for those units. Each unit must have, on a front façade, its own principal entrance. The entrance shall be a roofed concrete landing a minimum of three (3) feet by five (5) feet pursuant to section 47-18.33.B.6.
- 4. Pools, pool deck and fence/wall shall not encroach into the required pedestrian/utility easements.
- 5. Provide calculation indicating a twenty-five (25%) percent of the townhouse group's front façade setbacks an additional five (5) feet from the rest of the front façade pursuant to section 47-18.33.B.3.
- 6. Indicate the location of all mechanical equipment.
- 7. Provide the building height dimension form grade as defined in section 47-2.
- 8. Additional comments may be discussed at DRC meeting.